



Elite Insulation and PolyPro
Attention: Ken Wells

Dear Ken,

This letter is in response to your question concerning the FL 500 spray applied insulation and the use of this material on steel sprinkler pipes.

The FL 500 will not damage, corrode or impair the steel sprinkler pipe in any manner. Although the overspray may change the surface color and texture slightly it will not harm the pipe. The pipe can be completely encapsulated if desired with the FL 500 with no effect on the performance of the pipe.

As soon as the material has become a solid, or completed the reaction which changes the liquid to a solid the material becomes inert. The inert condition or classification of this material is why it is allowed to be disposed of in any landfill without any specialized treatment.

If you have any questions regarding this application, please feel free to call me at any time.

A handwritten signature in black ink, appearing to read "Steven W. Williams".

Steven W. Williams
Technical Director
Lapolla Industries, Inc.
15402 Vantage Parkway East,
Suite 322
Houston, Texas 77032
281-219-4100